

OFFICE OF THE JUNIOR CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT LABORATORY, JHALAWAR -326001 (Raj.)
CHEMICAL EXAMINATION REPORT OF WATER

No. 720


Date :- 01/09/2022

To,
✓ Principal
Sankalp Academy Sr. Sec. School
Jhalawar (Raj)
Reference - Your Lt. No. 288 Date:- 17/08/2022
Sample Not Collected by Lab

Block :- Jhalarapatan
Dist. -Jhalawar
GP- Salotiya
Date of exam- 23/08/2022
Date of recpt.-17/08/2022
Sample taker- Sh. Harish Dhakad

Code no.	Permissible limits	R
Particulars		Open Well Mohammad Alam, Gram- Kishanpuriya, Sankalp Academy Sr. Sec. School, Kota Road, Jhalawar (Raj.)
Village /Town		Jhirniya
Date of Collection		17-08-2022
Lab. Sample no.		PC-35
NOTE- ALL RESULTS EXCEPT Ph are in mg/l		
1. pH	6.5-8.5	7.9
2. Turbidity (NTU)	Less Than 5 NTU	0.8
3. Colour	Inoffensive	ND
4. Odour	Inoffensive	U.O
5. Total Alakanity	600 mg/l	320
6. Total Hardness (as CaCO ₃)	600 mg/l	440
7 chloride (as Cl)	1000 mg/l	40
8. Nitrate [as No ₃]	45 mg/l	27
9. Total Dissolved solids	2000 mg/l	679
10. Fluoride	More than 0.2	0.33
11. Residual Chlorine	Less than 1.5 mg/l	Nil

Remarks :- Sample were not collected by this lab


for Junior Chemist
PHED District Lab. Jhalawar
Date :-

No.

Copy to.-

1. The Chief Chemist PHED Rajasthan Jaipur
2. The Senior. PHED Regional Lab kota

Junior Chemist
PHED District Lab. Jhalawar